



- (2) **Equipment and protective systems intended for use in potentially explosive atmospheres
Directive 94/9/EC**

(1) **EC-TYPE EXAMINATION CERTIFICATE**

- (3) Number of the EC type examination certificate: **INERIS 13ATEX0020X**

- (4) Equipment or protective system:

LIMIT SWITCH TYPE LIMITEX xMICRO 00x

- (5) Manufacturer: **COEL MOTORI S.r.l**
(6) Address: **Via Campania, 40
I-20090 Fizzonasco di Pieve Emanuele (MI)**

- (7) This equipment or protective system and any other acceptable alternative of this one are described in the annex of this certificate and the descriptive documents quoted in this annex.
- (8) INERIS, notified body and identified under number 0080, in accordance with article 9 of Council Directive 94/9/EC of the 23rd March 1994, certifies that this equipment or protective system fulfils the Essential of Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, described in annex II of the Directive.

The examinations and the tests are consigned in report No 026732/13.

- (9) The respect of the Essential Health and Safety Requirements is ensured by:

- conformity with:

EN 60079-0 : 2009
EN 60079-1 : 2007
EN 60079-31 : 2009

- specific solutions adopted by the manufacturer to meet the Essential Health and Safety Requirements described in the descriptive documents.

- (10) Sign X, when it is placed following the Number of the EC type examination certificate, indicates that this equipment and protective system is subjected to the special conditions for safe use, mentioned in the annex of this certificate.
- (11) This EC type examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system, these are not covered by this certificate.
- (12) The marking of the equipment or the protective system will have to contain:

 II 2 GD or I M2

Verneuil-en-Halatte, 2013.09.18



The Chief Executive Officer of INERIS,
By delegation
T. HOUEIX
Ex Certification Officer

(13)

ANNEX

(14)

EC TYPE EXAMINATION CERTIFICATE N° INERIS 13ATEX0020X

(15)

DESCRIPTION OF THE EQUIPMENT OR THE PROTECTIVE SYSTEM

Limit switches type LIMITEK consist of an enclosure made in cast iron including electrical contacts. These limit switches are available in 2 different connection switch types: rotary and position.

The equipments are protected by the type of protection "d" and "tb".

The enclosures get the degrees of protection IP66 in accordance with EN 60529 standard.


PARAMETERS RELATING TO THE SAFETY

Maximum supply voltage : 300 Vac
Maximum intensity : 3 A
Maximum dissipated Power : 2 W
Nominal frequency : 50/60 Hz

MARKING

Marking has to be readable and indelible; it has to include the following indications:

COEL MOTORI S.r.l
I-20090 Fizzonasco di Pieve Emanuele (MI)
LIMITEK xMICRO 00x (1)
INERIS 13ATEX0020X
(Serial number)
(Year of construction)

 II 2 GD or I M2

Ex d I Mb

Ex d IIB T6 Gb or Ex d IIC T6 Gb

Ex tb IIIC T85°C Db IP66

-20°C ≤ Tamb ≤ +60°C or -50°C ≤ Tamb ≤ +60°C

WARNING: DO NOT OPEN IF ANY EXPLOSIVE ATMOSPHERE MAY BE PRESENT.

(1) Type is completed by numbers and /or letters corresponding to manufacturing variations.

Marking may be carried out in the language of the country of use.

The protective system or equipment has also to carry the marking normally stipulated by its construction standards.

ROUTINE EXAMINATIONS AND TESTS

In accordance with clause 16.2 of the EN 60079-1 standard, the equipment defined above is exempted of routine test in owing to the fact that it has undergone a static type test at 4 times the reference pressure under 44.1 bar.

(16) DESCRIPTIVE DOCUMENTS

The descriptive document quoted hereafter constitutes the technical documentation of the equipment, subject of this certificate.

- Certification file Lex-01 (8 rubrics)rev.0 dated and signed on 2013.04.03

(17) SPECIAL CONDITIONS FOR SAFE USE

- The gap and diametrical clearances are less than the values specified in the tables of the EN 60079-1 standard.
- The width of the flameproof joints is superior than the values specified in tables of EN 60079-1 standard.
- For group I, the user shall take into consideration that the equipments underwent only a shock test corresponding to a low risk energy.

The other conditions are stipulated in the instructions.

(18) ESSENTIAL SAFETY AND HEALTH REQUIREMENTS

The respect of the Essential Health and Safety Requirements is ensured by:

- Conformity to the standards quoted in clause (9).
- All provisions adopted by the manufacturer and defined in the descriptive documents.